

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 1 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

SCHEDULE A

EARNED PREMIUM AND LOSS EXPERIENCE INFORMATION

This schedule contains earned premium and loss experience information for the past five (5) years.

I. HISTORICAL INFORMATION

| POLICY PERIOD | AGENT OF RECORD | COMPANY |
|-----------------|----------------------------|---|
| 07-01-2001/2004 | Risk Services of Louisiana | Hartford Steam Boiler Inspection & Insurance Company |
| 07-01-2004/2007 | Risk Services of Louisiana | |

| POLICY PERIOD | NET PREMIUM | POLICY LIMITS | | ORM RETENTION |
|------------------|-------------|-----------------|--|--|
| | | BUSINESS INCOME | OTHER COVERAGES | |
| 07-01-2001/2002 | 542,778 | 272,369,232 | 15,000,000 Liability | \$50,000 Combined Single Limit Per Accident |
| 07-01-2002/2003 | 591,473 | 271,580,438 | 5,000,000 Extra Expense | |
| 07-01-2003/2004 | 613,047 | 277,110,195 | 250,000 Water Damage | |
| 07-01-2004/2005 | 640,416 | 273,946,073 | 250,000 Ammonia Contamination | |
| 07-01-2005/2006 | 710,304 | 308,649,993 | 250,000 Hazardous Substance | |
| 07-01-2006/2007* | 797,261 | 259,902,645 | 250,000 Consequential Damage 250,000 Expediting Expense | |

II. LOSS EXPERIENCE (as of 2/14/07)

| POLICY PERIOD | NUMBER OF LOSSES INCURRED | TOTAL LOSSES INCURRED BY ORM | TOTAL LOSSES INCURRED BY EXCESS CARRIER | LARGEST SINGLE LOSS |
|------------------------|---------------------------|------------------------------|---|---------------------|
| 07-01-2001/2002 | 55 | 555,559 | -0- | 37,940 |
| 07-01-2002/2003 | 81 | 1,057,116 | 228,841 | 172,795 |
| 07-01-2003/2004 | 55 | 739,536 | 48,658 | 97,223 |
| 07-01/2004/2005 | 51 | 657,144 | 8,936 | 58,936 |
| 07-01-2005/2006 | 50 | 1,163,622 | 119,221 | 125,000 |
| 07-01-2006/01-31-2007* | 35 | 600,781 | 47,126 | 78,873 |

* as of 2/5/07

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 2 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

III. DETAIL LOSS EXPERIENCE

The following reports reflect detail information for losses over \$10,000.

07-01-2001/2002 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | St | Paid Total | Incurred Total |
|-------------------------|-----------|--|----|-------------------|-------------------|
| 0585 | 6/28/2002 | FLOAT SWITCH STUCK CAUSING OVERFLOW | F | 17,712.41 | 17,712.41 |
| 5040 | 6/25/2002 | U/G FEEDER FAULTED CAUSING 2-MOTORS TO SINGLEPHASE IN CENTRAL PLANT 75HP EACH | F | 29,236.95 | 29,236.95 |
| 6060 | 6/10/2002 | YORK A/C COMPRESSOR AND CONTROLS GROUND FAUTER | F | 11,548.00 | 11,548.00 |
| 1580 | 6/2/2002 | 30-TON TRANE COMPRESSOR AND CONTACTS DMG BY SIN-GLE PHASING @ CONTRYSIDE HOME #100 & 200 | F | 11,635.33 | 11,635.33 |
| 1580 | 6/1/2002 | 30-TON TRANE COMPRESSOR GROUNDED @ DOVER CENTER | F | 20,200.00 | 20,200.00 |
| 5220 | 5/8/2002 | OPEN DRIVE TRANE COMPRESSOR THREW ROD @ SCHOOLOR NURSING | F | 13,157.07 | 13,157.07 |
| 1580 | 4/30/2002 | 85-TON TRANE THREW A ROD @ LAUNDY MECHANICAL POD | F | 16,115.05 | 16,115.05 |
| 5160 | 4/29/2002 | SINGLE PHASE CAUSED DAMAGE TO EQUIP | F | 10,426.35 | 10,426.35 |
| 4420 | 4/18/2002 | FEEDER FOR #63A @ ASTER ST. SUB-STATION FAULTED | F | 37,940.00 | 37,940.00 |
| 0438 | 4/1/2002 | ALL 3-CARRIER CHILL PACS NEED REPAIRS BERG GOTBID | F | 22,507.50 | 22,507.50 |
| 5260 | 3/15/2002 | YORK 400-TON SCREW CHILLER INBOARD ROTOR FAILED@ MARTIN HALL | F | 16,460.25 | 16,460.25 |
| 5000 | 3/6/2002 | CITY OF RUSTON SUBSTATION FAULTED-SINGLE PHASENUMEROUS MOTORS AND OTHER EQUIPMENT | F | 23,139.42 | 23,139.42 |
| 4620 | 2/26/2002 | 2-15-TON TRANE COMPRESSORS SINGLED PHASED @GREENHOUSE | F | 10,216.92 | 10,216.92 |
| 5040 | 10/2/2001 | 2-CHILLER AND 20+ PUMPS DMG WHEN SAND ENTEREDLOOP | F | 26,090.59 | 26,090.59 |
| 0438 | 9/21/2001 | #1 TRANE CHILLER GROUNDED AT HARVEY STATE OFFICEBLDG | F | 19,764.00 | 19,764.00 |
| 0571 | 9/19/2001 | 100 TON TRANE SINGLED PHASED @ 1440 HWY90 BRIDGECITY | F | 32,474.75 | 32,474.75 |
| 5260 | 8/16/2001 | YORK YCAJ44HE8-41PA (CHILLER #1) GROUNDED @ ATHLETIC OFFICE | F | 17,095.45 | 17,095.45 |
| 4620 | 8/1/2001 | 2400 VOLT TXFM GROUNDED @ NW CORNER MUSEUM OFARTS | F | 22,680.00 | 22,680.00 |
| 1720 | 7/27/2001 | 65-TON RECIPRICAL CARRIER GROUNDED-VIBRATION AL-SO DID CONDENSOR DAMAGE | F | 17,040.00 | 17,040.00 |
| 5040 | 7/27/2001 | GEARBOX ON CERAMIC COOLING TOWER FAILED ATCENTRAL PLANT | F | 10,130.00 | 10,130.00 |
| 1420 | 7/26/2001 | TREE LIMB FELL AND CAUSED SINGLE PHASING/NUMER- OUS A/C,ELECTRIC MOTORS DAMAGE | F | 18,872.44 | 18,872.44 |
| 5260 | 7/23/2001 | YORK COMPRESSOR SINGLED PHASED | F | 17,801.39 | 17,801.39 |
| 1460 | 7/18/2001 | 260-TON TRANE CHILLER/GROUNDED MOTOR | F | 24,947.00 | 24,947.00 |
| 2835 | 7/16/2001 | SINGLE PHASING DAMAGED NUMEROUS A/C MOTORS ETC. | F | 15,156.95 | 15,156.95 |
| Total By Period: | | | | 24 | Claims |
| | | | | 462,347.82 | 462,347.82 |

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 3 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

07-01-2002/2003 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | Stat | Paid Total | Incurred Total |
|-------------------------|------------|--|------|-------------------|-------------------|
| 4461 | 6/23/2003 | POWER SPIKE DAMAGED 3 MCQUAY COMPRESSORS | F | 18,663.12 | 18,663.12 |
| 5040 | 6/17/2003 | CENTRAL PLANT TOWER #1 GEARBOX TRANSMISSION SEIZED AND FAILED | F | 14,979.37 | 14,979.37 |
| 4420 | 6/9/2003 | WEST AHU POWER WHEEL ASSEMBLE BROKE AT PLEASANTHALL ATTIC (W.O.# 73033) | F | 40,721.95 | 40,721.95 |
| 0650 | 5/13/2003 | 770-TON TRANE GROUNDED | F | 19,752.00 | 19,752.00 |
| 0926 | 5/13/2003 | HIGH VOLTAGE SWITCH #30 FAULTED / GE SWITCHGEARFAILED ON 2ND. FLOOR VAULT AT CHARITY | O | 0.00 | 49,000.00 |
| 4650 | 5/5/2003 | 15KVA TXFM FAULTED AT HEALTH & PHYSICAL BLDG | F | 42,480.51 | 42,480.51 |
| 5260 | 5/2/2003 | 225- TON TRANE CENTRIFUGAL LOST OIL PRESSURE @ BOURGEOIS HALL | F | 25,775.99 | 25,775.99 |
| 1200 | 5/1/2003 | CLEAVER BROOKS MODEL STEAM BOILER OVERFIRING & LOW WATER CONDITION/ COMPLETE SAFETY FAILURE | F | 23,962.83 | 23,962.83 |
| 4622 | 4/30/2003 | ELECTRICAL BUSS TO FELTON CLARK FIELD FAULTED | F | 40,965.43 | 40,965.43 |
| 0438 | 4/25/2003 | ATC ON EMERGENCY GENERATOR FAILED AND GROUND FAULT OCCURED TO CONTROLS AND OTHER EQUIPMENT | F | 36,270.00 | 36,270.00 |
| 4420 | 4/7/2003 | POWER SPIKE CAUSED INSULATOR TO FAIL ON 4160VOLT BUSS BAR AT SUBSTATION/TWO REACTORS DMG | F | 49,000.00 | 49,000.00 |
| 4650 | 1/2/2003 | MAIN HIGH VOLTAGE SWITCHGEAR FIRE AND RELATED FAULTS, ETC | F | 49,000.00 | 49,000.00 |
| 5040 | 12/27/2002 | SOUTH FEEDER SWITCH FAILED CAUSING CAMPUS-WIDE POWER FAILURE | F | 10,091.17 | 10,091.17 |
| 4650 | 12/6/2002 | UNDER GROUND FEEDER FAULT IN D SECTION | F | 49,000.00 | 49,000.00 |
| 4440 | 11/18/2002 | MAIN CHILLER STARTER FAILED AGAIN. SEE: 03B/0920LSU-A FOR ORIGINAL CLAIM & DETAILS | F | 45,696.39 | 45,696.39 |
| 4620 | 11/17/2002 | AIR HANDLER FAILED @ T T ALLAIN HALL | F | 25,991.57 | 25,991.57 |
| 4420 | 11/12/2002 | C/W FLOW SWITCH FAILED CAUSING DAMAGE TO BOTH COMPRESSORS ON 110 TON UNIT M: YCWZ88RP-46PB | F | 15,444.00 | 15,444.00 |
| 2184 | 10/30/2002 | 6-POLE TXFMS DAMAGED BY ENTERGY EQUIPMENT FAILURE SWITCH CABINET FAULTED CAUSING POWER FAILURE | F | 16,902.00 | 16,902.00 |
| 5040 | 10/24/2002 | IN 11 BLDGS, AND FLUCTUATIONS IN OTHER FEEDER LOOPS | F | 17,132.97 | 17,132.97 |
| 0926 | 10/23/2002 | 480 VOLT BUS DUCT GROUNDED AT WEST SIDE OF HOSPITAL AGENTS SPOILED DUE TO NO POWER | F | 17,856.44 | 17,856.44 |
| 4420 | 10/6/2002 | FAILURE OF TURBINE CHILLER AT #6 POWERHOUSE | F | 49,000.00 | 49,000.00 |
| 0914 | 10/3/2002 | HURRICANE LILLIE CAUSE POWER SURGES CHILLER AND SERVICE LOAD CENTER @ ENGLAND DMG | F | 28,650.00 | 28,650.00 |
| 1720 | 10/3/2002 | KOHLER GENERATOR GROUNDED OUT DURING HURRICANE LILLIE/ PETROVEN GAS PUMP ALSO GROUNDED | F | 14,916.32 | 14,916.32 |
| 2055 | 10/3/2002 | CRACKED MANIFOLD ON #1 CUMMINS GENERATOR ALLOWED WATER TO ENTER DIESEL ENGINE | F | 14,553.16 | 14,553.16 |
| 4420 | 10/2/2002 | FAULT AT POWERHOUSE CAUSED DAMAGE TO FEEDER 3E | F | 17,064.19 | 17,064.19 |
| 4440 | 9/20/2002 | DUAL COIL WESTINGHOUSE TXFM BURNED ON TRANE CVH CAUSING THE NEED FOR RENTAL UNIT | F | 43,229.00 | 43,229.00 |
| 5160 | 9/17/2002 | 400-TON TRANE CENTRIFUGAL GROUNDED @ COLISEUM-LABOR ONLY | F | 23,217.00 | 23,217.00 |
| 4540 | 9/4/2002 | YORK CHILLER MODEL YCWZ88MR6 HAD CONDENSER COIL FAILURE DUE TO VIBRATION. | O | 0.00 | 18,000.00 |
| 5040 | 7/29/2002 | 22 Y/O PAD MOUNTED TRANSFORMER FAILED AT PINEHAVEN APARTMENTS | F | 23,290.55 | 23,290.55 |
| 2210 | 7/16/2002 | POWER SURGE CAUSED 3-800 TRANE COMPRESSORS TO GO TO GROUND FAULT | F | 13,606.39 | 13,606.39 |
| 5040 | 7/12/2002 | COOLING TOWER FAN BACK-DRAFTED CAUSING 2-SHAFTS TO CRACK OR BREAK WHEN MOTOR STARTED | F | 12,792.43 | 12,792.43 |
| 4420 | 7/7/2002 | LIGHTNING DAMAGED ENERGY MANAGEMENT SYSTEM | F | 34,775.64 | 34,775.64 |
| Total By Period: | | | | 32 | Claims |
| | | | | 834,780.42 | 901,780.42 |

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 4 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

07-01-2003/2004 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | St | Paid Total | Incurred Total |
|-------------------------|------------|---|----|-------------------|-------------------|
| 1767 | 6/5/2004 | TRW CAUSED SINGLE PHASING/ TWO 5-TON UNITS SINGLPHASED @ J. BRISCO FAMILY DISORDERS CLINIC | F | 10,786.50 | 10,786.50 |
| 4500 | 4/26/2004 | YORK MILLENNIUM -VSD LIQUID CHILLING SYSTEMOPEN DRIVE MOTOR FAULTED | F | 12,450.00 | 12,450.00 |
| 5040 | 4/7/2004 | GEARBOX SHAFT ON TOWER FAN #3 BROKE ON START UP. MSU # 03-27 | F | 15,151.19 | 15,151.19 |
| 4420 | 3/28/2004 | CAT CRAWLED INTO 5KVA REGULATOR AND CAUSED GROUND FAULT | F | 39,000.00 | 39,000.00 |
| 4620 | 2/6/2004 | UNDERGROUND 15KVA CABLE FAULT NORTH OF RAVINE(OCTAVIA,SATTERWHITE, J.B. MOORE & CLARK HALL | F | 16,870.00 | 16,870.00 |
| 1420 | 2/3/2004 | TXFM WENT TO GROUND AT OAKCREST AND UNDERGROUND 15 KV FEEDS GROUNDED BETWEEN OAKCREST AND COLD STORAGE. | F | 34,280.40 | 34,280.40 |
| 5262 | 1/21/2004 | 13.5VOLT 750 KVA DRY TXFM WENT TO GROUND ATCAJUNDOME | F | 12,944.63 | 12,944.63 |
| 4620 | 1/5/2004 | 750KVA 13.8DELTA 208/120 PAID TXFM FAILED@ WILLIAM WALLACE STEWART HALL(WATER INTRUSION) | F | 23,500.00 | 23,500.00 |
| 1420 | 12/21/2003 | UNDERGROUND CABLE FAULT / DAMAGED TWO TXFMS | F | 49,448.78 | 49,448.78 |
| 0926 | 12/5/2003 | 4000 AMP ELECTRICAL BUSS FAILED ON ROOF TO PENT-HOUSE | F | 49,000.00 | 49,000.00 |
| 5910 | 11/26/2003 | AUTOMATIC SWITCH FOR GENERATOR FAULTED DURINGPOWER SURGE | F | 30,939.56 | 30,939.56 |
| 4420 | 11/25/2003 | 1000 TON YORK COMPRESSOR VANES FAILED AT LIFESCIENCE BLDG | F | 42,202.00 | 42,202.00 |
| 1580 | 11/9/2003 | SINGLE PHASING CAUSED NUMEROUS MOTOR AND EQUIP | F | 25,351.48 | 25,351.48 |
| 0256 | 10/8/2003 | VENTURA-PVI 250 GAL HOT WATER HEATER TUBES CRACK | F | 12,500.00 | 12,500.00 |
| 1580 | 9/25/2003 | OLD 13.3KVA UNDERGROUND CABLE FAULTED AND DAMAGE750 KVA TXFM. CAPITOL OUTLAY PAID REPAIRS EXCEPT | F | 30,209.93 | 30,209.93 |
| 4540 | 8/27/2003 | MCQUAY CHILLER HAD TWO COMPRESSORS GO TO GROUND. | O | 0.00 | 35,000.00 |
| 2080 | 8/27/2003 | POWER SURGE CAUSED PRIMARY WINDINGS ON TXFMTRANSFORMER TO FAULT BEHIND CHAPEL | F | 13,808.30 | 13,808.30 |
| 4540 | 8/27/2003 | MCQUAY CHILLERS @ AQUACLTURE CENTER AT BEN HER RESEARCH STATION BEARING FAILURE TO BOTH COMPRESSORS | F | 14,930.08 | 14,930.08 |
| 4620 | 8/19/2003 | SINGLE PHASING DAMAGED VARIABLE FQ DRIVES FOR AHNO.3,4, & 5 ALONG WITH PUMPS @ CO-OP EXTENSION BLD | F | 33,456.42 | 33,456.42 |
| 5040 | 8/19/2003 | 15 TON CHILLER AT DOLAND ATHLETIC FIELD HOUSEGROUNDED | F | 12,674.35 | 12,674.35 |
| 5220 | 8/12/2003 | BOTH COMPRESSORS ON YORK 80 TON CHILLER FAILED@ EAST STADIUM (STRAWBERRY) | F | 12,360.78 | 12,360.78 |
| 4420 | 7/25/2003 | CHILLER NO 1 OIL PUMP FAILURE @ POWERHOUSE | F | 45,454.25 | 45,454.25 |
| 4420 | 7/15/2003 | STATOR BARS IN RELIANCE MOTOR IN A YORK 2000 - TON CHILLER CAME LOSS AND DAMAGED THE MOTOR ON CHILLER NO. 2 | F | 49,000.00 | 49,000.00 |
| Total By Period: | | | | 23 | Claims |
| | | | | 586,318.65 | 621,318.65 |

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 5 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

07-01-2004/2005 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | St | Paid Total | Incurred Total |
|-------------------------|------------|--|----|-------------------|-------------------|
| 5910 | 6/24/2005 | TRANSMISSION LINE OVERCHARGED BY EMPLOYEE. TRANSMISSION LINE RUPTURED CAUSING COLLATERAL DAMAGE TO THE ANTENNA. | F | 15,340.17 | 15,340.17 |
| 7315 | 5/23/2005 | TRANSFORMER WENT TO GROUND | F | 39,741.00 | 39,741.00 |
| 1420 | 5/6/2005 | TRANE 100-TON CHILLER HIGH PRESSURE FAILED AND ALLOWED EXCESS PRESSUE TO DAMAGE CONDENSOR AND EVAPORATOR TUBE BUNDLES. UNIT WAS FOR GABRIEL HOUSE [S02554] | O | 0.00 | 49,000.00 |
| 5160 | 4/21/2005 | UNDERGROUND CABLE FAULT ON 13.5KVA LINES BETWEEN ROY HALL TRANSFORMER AND PRESIDENT'S HOME TRANSFORMER | F | 10,471.98 | 10,471.98 |
| 4540 | 4/10/2005 | 25 - TON DX CONDENSING UNIT SINGLE PHASED AT GOURRIER LANE GREENHOUSE | F | 17,338.75 | 17,338.75 |
| 5160 | 3/15/2005 | 500 -TON TRANE CENTRIFUGAL CHILLER AT WARREN EASTON CHILLER STATION SEMIHERMATIC MOTOR WENT TO GROUND | F | 49,000.00 | 49,000.00 |
| 1580 | 3/2/2005 | TWO SCROLL 15-TON COMPRESSORS LOCKED UP. COUNTRYSIDE | F | 26,426.04 | 26,426.04 |
| 4620 | 1/12/2005 | 750 KVA DRY TXFM GROUNDED @ BASEMENT OF DUNN HALL. WATER FROM DISHWASHER ON FIRST FLOOR DRIPPED ONTO THE CABINET OF THE TXFM AND APPARENTLY CAUSED INTERNAL GROUNDING. | F | 37,683.00 | 37,683.00 |
| 5160 | 1/4/2005 | UNDERGROUND CABLE FAULT ON 15 KVA SYSTEM SINGLE PHASING CAUSED DAMAGES TO OTHER EQUIPMENT. | F | 36,831.10 | 36,831.10 |
| 4622 | 12/18/2004 | SUMP PUMP IN BASEMENT OF FELTON GRANDISON HALL FAILED DURING CHRISTMAS BREAK AND WATER BACKUPED TO APROX. SIX FEET. ELECTRICAL EQUIPMENT DAMAGED | F | 19,449.00 | 19,449.00 |
| 4650 | 11/10/2004 | SWITCHGEAR AT MULTI-PURPOSE BUILDING FAILED CAUSING OUTAGE TO 6 OF THE 11 BUILDINGS. | F | 34,332.54 | 34,332.54 |
| 1720 | 9/24/2004 | UNDERGROUND CABLE FAULT ALSO DAMAGED 225 KVA TXFM | F | 18,529.98 | 18,529.98 |
| 4460 | 8/16/2004 | MCQUAY 2200 - TON CHILLER NO. 1 SUSTAINED A LUBRICATON FAILURE AND DAMAGED CHILLER | O | 0.00 | 40,000.00 |
| 5160 | 8/15/2004 | CITY OF NATCHITOCHEH HAD TREE LIMB ON LAKE ST. TO FALL ACROSS THEIR LINES. SINGEL PHASING OCCURED ON WEST FEED- FIELD HOUSE | F | 49,000.00 | 49,000.00 |
| 4460 | 8/12/2004 | OIL PUMP FAILED ON MCQUAY 2200 - TON COMPRESSOR #2 UNIT | O | 0.00 | 40,000.00 |
| 4440 | 8/9/2004 | BOLTON LIBRARY TRANSFORMER GROUNDED BY OPOSSUM! | F | 17,060.66 | 17,060.66 |
| 4420 | 7/23/2004 | SQUARE-D 1500 KVA TRANSFORMER, 480y/277 WENT TO GROUND AT MADDOX FIELD HOUSE. | F | 13,258.42 | 13,258.42 |
| 4485 | 7/21/2004 | GAMMA CAMERA AND LASER FILM PROCESSOR POWER SUPPLIES DAMAGED ON SUBSEQUENT REENTERGIZING ELECTRICAL CIRCUITS | F | 17,027.72 | 17,027.72 |
| 4620 | 7/20/2004 | THREE 50 KVA POLE MOUNTED TRANSFORMERS DEVELOPED A GROUND FAULT AND ARCHED AT DIARY FARM. | F | 11,025.00 | 11,025.00 |
| Total By Period: | | | | 19 | Claims |
| | | | | 412,515.36 | 541,515.36 |

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 6 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

07-01-2005/2006 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | St | Paid Total | IncurOred Total |
|-------------------------|------------|--|----|-------------------|---------------------|
| 2080 | 6/12/2006 | ONAN 155 KW DIESEL GENERATOR WENT TO GROUND. UNIT IS OVER 30 YEARS IN AGE. | F | 25,294.00 | 25,294.00 |
| 4420 | 5/4/2006 | CLEAVER BROOKS MODEL CBF700250, 125 HP, BOILER DEVELOPED LEAKS, LEAKING TUBES. | O | 0.00 | 49,000.00 |
| 4415 | 4/18/2006 | 1350 TON- TRANE CHILLER FAILED WHEN WATER ENTERED REFRIGERENT. CONDENSOR TUBE FAILED AND MOTOR WENT TO GROUND. | F | 41,804.40 | 41,804.40 |
| 1200 | 4/3/2006 | # 2 CHILLER - 270 TON WESTINGHOUSE CENTRIFICAL DOWN DUE TO OIL FAILURE | O | 230,774.00 | 295,000.00 |
| 0438 | 3/16/2006 | 1600 AMP MAIN BREAKER SUSTAINED GROUND FAULT DURING A POWER SURGE. GROUND FAULT PROTECTION DEVICE DAMAGED BREAKER. | F | 15,687.50 | 15,687.50 |
| 0909 | 3/11/2006 | TWO TRANE 60- TON COMPRESSORS LOCKED UP DUE TO OIL PUMP FAILURE | O | 0.00 | 25,000.00 |
| 4620 | 2/26/2006 | TRANE AIR HANDLER FAILED AND FLOODED 1/2 OF BASEMENT OF T.T. ALLAIN HALL. [S02167] | O | 145,777.05 | 170,000.00 |
| 4500 | 1/2/2006 | 1000- TON YORK VSD CHILLING SYSTEM HAD MOTOR GO TO GROUND | F | 15,200.00 | 15,200.00 |
| 2060 | 12/25/2005 | IVECO 7.5 LITER DIESEL ENGINE SUSTAINED BEARING FAILURE AND LOCKUP ON A 120 KW GENERATOR. | F | 13,491.41 | 13,491.41 |
| 2100 | 12/25/2005 | RACCOON CAUSED SINGLE PHASING ON 15 KVA FEEDS. POWER POLE, LIGHTNING ARRESTOR, CROSS ARMS, CUTOUTS, FUSES, AND OTHER ELECTRICAL APPARATUS ARCHED AND CAUGHT FIRE. COON FIRED! ONE OF EMERGENCY GENERATORS FAILED ALSO. | F | 60,820.19 | 60,820.19 |
| 4820 | 12/2/2005 | ONE OF TWO COMPRESSORS FAILED WHEN SPLIT CHILLER BARREL ALLOWED WATER TO ENTER THE REFRIGERANT SYSTEM. | F | 14,643.75 | 14,643.75 |
| 4620 | 11/17/2005 | HOT WATER HEATER LEAKED AND CAUSED TRANSFORMER TO GROUND OUT AT BETHUNE HALL | F | 13,273.00 | 13,273.00 |
| 4460 | 10/12/2005 | 13800 V/480-277V; 750 KVA DRY TRANSFORMER HAD A GROUND FAULT IN THE HIGH VOLTAGE PRIMARY WINDING ON B PH FOR THE MATH BUILDING | F | 33,021.00 | 33,021.00 |
| 2225 | 9/24/2005 | EMERGENCY GENERATOR MALFUNCTIONED AND RAN BACKWARDS - THREE AC RAN BACKWARD AND BURN UP THE COMPRESSORS | F | 16,317.62 | 16,317.62 |
| 4420 | 9/24/2005 | CHILLER # 3 DAMAGED DURING POWER SURGE - | F | 34,150.00 | 34,150.00 |
| 4420 | 9/23/2005 | 5 KVA 13.8 /4.16 KV OIL FILLED TRANSFORMER SUSTAINED GROUND FAULT. | O | 0.00 | 20,000.00 |
| 4420 | 9/3/2005 | YORK COMPTESSOR (#2) SINGLE PHASED AT LSU SYSTEMS BUILDING | F | 16,703.00 | 16,703.00 |
| 4820 | 8/31/2005 | SINGLE PHASING AFTER RENEGIZING POWER LINES CAUSED COMPRESSOR AT BETSY CHERAMIE AYO HALL TO GROUND AND A 1000 AMP BREAKER AND TRANSFORMER AT PELTIER HALL WENT TO GROUND | F | 29,760.60 | 29,760.60 |
| 0924 | 8/29/2005 | SINGLE PHASING CAUSED TWO YORK CHILLER MOTORS TO GO TO GROUND DURING TIME HOSPITAL RAN ON EMERGENCY POWER. | F | 30,712.83 | 30,712.83 |
| 4620 | 8/24/2005 | 750 KVA THREE PHASE PAD MOUNTED TRANSFORMER GROUND FORM WATER INTRUSION AT SCHOOL OF NURSING | F | 37,015.00 | 37,015.00 |
| 1580 | 8/23/2005 | 60 TON TRANE CHILLER FAILED WHEN CHILLER BARREL TUBES FROZE AND RUPTURED TUBES. COMPRESSOR DAMAGED WHEN UNIT CONTINUED TO OPPERATE WITH WATER INSTEAD OF REFRIGERENT. | F | 49,000.00 | 49,000.00 |
| 4420 | 8/17/2005 | ONAN GENERATOR S/N D010225956 INJECTOR ON CYLINDER #2 BROKE AND DAMAGED ENGINE. | R | 31,135.22 | 33,135.22 |
| 5260 | 8/15/2005 | 750 KVA PAD MOUNDED TRANSFORMER HAD CRACKED "B" AND "C" BUSHINGS ON THE SECONDARY SIDE AND TWO PIN HOLES IN WELDED SEAMS OF THE TANK AT MAXIM DOUCET HALL. | F | 21,500.00 | 21,500.00 |
| 5040 | 8/9/2005 | COOLING TOWER FAN #1 SHAFT BROKE DURING STARTUP. | O | 0.00 | 15,000.00 |
| 5040 | 8/6/2005 | TRANSFORMER ON SOUTH FEEDER SERVING GAYLE HALL GROUNDED. GROUND FAULT ALSO CAUSED SWITCHGEAR TO MALFUNCTION | F | 19,041.57 | 19,041.57 |
| 4680 | 7/15/2005 | UNDERGROUND CABLE FAULT- APPROXIMATELY 500- 900 FEET OF CABLE | F | 39,755.61 | 39,755.61 |
| Total By Period: | | | | 26 | Claims |
| | | | | 934,877.75 | 1,134,326.70 |

| | | | | | | |
|--|---|--|---|----------------|---|--------|
| PROPOSAL NO. | * | INVITATION FOR BID | * | DATE | * | PAGE |
| | * | SCHEDULE A | * | | * | |
| BM-10 | * | EARNED PREMIUM & LOSS EXPERIENCE INFO | * | April 18, 2007 | * | 7 of 7 |
| THIS SCHEDULE DOES NOT NEED TO BE RETURNED. | | | | | | |

07-01-2006/01-31-2007 as of February 14, 2007

| Loca Code | Loss Date | Claim Description | St | Paid Total | Incurred Total |
|-------------------------|------------|--|----|------------------|-------------------|
| 4422 | 1/25/2007 | TURBINE DAMAGED | O | 0.00 | 75,000.00 |
| 0655 | 1/15/2007 | 100 HP THREE PHASE PUMP MOTOR DEVELOPED A GROUND FAULT. OTHER ELECTRICAL EQUIPMENT ALSO DEVELOPED FAULT. | O | 0.00 | 30,000.00 |
| 1420 | 12/13/2006 | UNDERGROUND 15 KVA FAULT AND TRANSFORMER DAMAGE FROM ITU BUILDING (S-02681) AND BIENVILLE HOUSE (S02684). | O | 20,869.00 | 20,869.00 |
| 2100 | 11/28/2006 | MCQUAY CHILLER FAILED WHEN CHILLED WATER LINE BROKE UNDER THE SLAB OF GENERATOR BUILDING. DAMAGES TO IMPELLOR, PINON, VALES, AND OTHER COMPONENTS. | O | 0.00 | 49,000.00 |
| 1420 | 11/13/2006 | UNDERGROND CABLE FAULT AND TRANSFORMER DAMAGE BETWEEN CEDERVIEW AND MAGNOLIA BUILDING | F | 18,841.00 | 18,841.00 |
| 4421 | 11/2/2006 | HOT WATER PUMP WITH 75 HP ELECTRIC MOTOR FAILED AND DAMAGED PIPING, AND OTHER EQUIPMENT. | O | 0.00 | 25,000.00 |
| 4420 | 10/20/2006 | TRANE #1 CHILLER AT LSU - SOUTH CAMPUS - GULF SOUTH PARKWAY ON G.S.R.I ROAD HAD COMPRESSOR MOTOR STARTER FAILURE. | O | 0.00 | 32,000.00 |
| 5160 | 10/2/2006 | TRANE , MODEL CVHA 044F MOTOR FAILED AT SUBSTATION #1 (NEAR VARNADO HALL) S-08177 | O | 0.00 | 23,964.00 |
| 1420 | 9/27/2006 | CONDENSING TUBES RUPTURED AND WATER ENTERED REFRIGERENT THAT GROUNDED TRANE COMPRESSOR AT EVANGELINE | O | 18,620.00 | 49,000.00 |
| 4421 | 9/13/2006 | VOLTAGE SURGES AND POWER BLACKOUTS CAUSED SINGLE PHASING TO CHILLER #4 AND DAMAGED BREAKER FOR CHILLER#4 AT COOK HOTEL AND ALUMNI CENTER | O | 0.00 | 25,000.00 |
| 5160 | 9/2/2006 | TRANE AIR HANLER ON THE FIRST FLOOR OF FOURNET HALL SUSTAINED BEARING FAILURE THAT DESTROYED THE FAN BLADES WHICH STUCK COILS | O | 0.00 | 19,000.00 |
| 4420 | 8/29/2006 | TRANE CHILLER #2 FAILED DUE TO GROUNDED STARTER AT SOUTH CAMPUS. | O | 0.00 | 25,000.00 |
| 4420 | 8/24/2006 | YORK NO. 2 CHILLER SUSTAINED BEARING FAILURE WHEN POWER FAILED. UNITS OIL PUMP DID NOT FUNCTION DURING WIND DOWN OF UNIT | O | 0.00 | 30,000.00 |
| 4420 | 8/23/2006 | AMERICAN STANDARD AIR HANDLER SQUAIRL CAGE BLOWER FAILED AND METAL DAMAGED THE COILS. CHILLED WATER LEAKED ON TO THE THIRD FLOOR. | O | 0.00 | 25,000.00 |
| 4460 | 8/21/2006 | UNILUX BOILER DEVELOPED SPLIT TUBES. | O | 0.00 | 40,000.00 |
| 4462 | 7/25/2006 | COMPRESSOR WENT TO GROUND IN WALK IN COOLER AT MAESTRI FIELD AT PRIVATEER PARK. CONTENTS SPOILED DUE TO LACK OF REFRIGERATION. | O | 0.00 | 10,000.00 |
| 4420 | 7/18/2006 | YORK CHILLER NO. 5 AT POWERHOUSE FAILED DUE TO OIL PUMP | O | 0.00 | 45,000.00 |
| Total By Period: | | | | 17 | Claims |
| | | | | 58,330.00 | 542,674.00 |